



Vimala Scientific Services Pvt. Ltd.

(AN ISO 9001-2008 CERTIFIED LABORATORY)

CENTRE OF QUALITY ANALYTICAL SERVICES



12-12-157/A, Ravindranagar, Seethaphalmandi, Secunderabad - 500 061. Ph : 2700 7561, Telefax : 2701 6941
Email : vimalab@gmail.com Mobile : 92462 16941

CERTIFICATE OF ANALYSIS

Drug. Lic. No. 1/AP/HD/ALJG/2001

Form 39 See rule 150-E (f) (Under the Drugs & Cosmetics Act 1940 & the Drugs & Cosmetics Rules 1945 thereunder)

Customer's Name & Address :
**EDIFY WORLD SCHOOL
BALAPUR
HYDERABAD.**

Reg. No. : **VSWM/AR/092**
Report Date : **20-06-2014**
Ref. No. : **—**
Reg. Date : **18-06-2014**

Sample Particulars :
**DETAILS OF THE SAMPLE: R.O WATER
TEST REQUIRED : CHEMICAL ANALYSIS.**

TEST RESULTS

**SPECIFICATIONS
(REQUIREMENT DESIRABLE
AS PER IS10500-1999)**

TEST	RESULT	SPECIFICATIONS
1. PHYSICAL PARAMETERS		
1. Colour (Hazen Units)	5	5
2. pH	7.0	6.5 to 8.5
3. Turbidity (NTU)	3	5
4. E.C. (Micro Siemns/cm)	90	—
2. CHEMICAL PARAMETERS		
5. Total Dissolved Solids (mg/l)	50	500
6. Total Hardness as CaCO ₃ (mg/l)	24	300
7. Calcium as Ca (mg/l)	16	75
8. Magnesium as Mg (mg/l)	8	30
9. Alkalinity to Methyl Orange as CaCO ₃ (mg/l)	20	200
10. Alkalinity to Phenolphthalein as CaCO ₃ (mg/l)	NIL	—

THE ABOVE WATER SAMPLE IS USEFULL FOR DRINKING PURPOSE

AUTHORISED SIGNATORY

D. Joshi

PRINCIPAL
EDIFY WORLD SCHOOL
Balapur, Hyderabad.



Vimala Scientific Services Pvt. Ltd.

(AN ISO 9001-2008 CERTIFIED LABORATORY)

CENTRE OF QUALITY ANALYTICAL SERVICES



12-12-157/A, Ravindranagar, Seethaphalmandi, Secunderabad - 500 061. Ph : 2700 7561, Telefax : 2701 6941
Email : vimalab@gmail.com Mobile : 92462 16941

CERTIFICATE OF ANALYSIS

Drug. Lic. No. 1/APHD/ALIG/2001

Form 39 See rule 150-E (f) (Under the Drugs & Cosmetics Act 1940 & the Drugs & Cosmetics Rules 1945 thereunder)

Customer's Name & Address :

EDIFY WORLD SCHOOL
BALAPUR
HYDERABAD.

Reg. No. : VSWMAR/092

Report Date : 20-06-2014

Ref. No. : —

Reg. Date : 18-06-2014

Sample Particulars :


**DETAILS OF THE SAMPLE: R.O WATER
TEST REQUIRED : CHEMICAL ANALYSIS.**

TEST	TEST RESULTS		SPECIFICATIONS
	RESULT		(REQUIREMENT DESIRABLE AS PER IS10500-1999)
11. Non-Carbonate hardness as CaCO ₃ (mg/l)	4		—
12. Sodium as Na (mg/l)	10		250
13. Chloride as Cl (mg/l)	8		250
14. Sulphate as SO ₄ (mg/l)	5		200
15. Silica as SiO ₂ (mg/l)	1.2		—
16. Iron as Fe ₂ O ₃ (mg/l)	0.03		0.3
17. Nitrates as NO ₃ (mg/l)	2		45
18. Fluoride as F (mg/l)	0.3		1.5
19. Potassium as K (mg/l)	1		—

THE ABOVE WATER SAMPLE IS USEFULL FOR DRINKING PURPOSE

V. Anish

D. Jishu


AUTHORISED SIGNATORY

1056 PRINCIPAL
EDIFY WORLD SCHOOL
Balapur, Hyderabad.