

**GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE AND FIRE SERVICE DEPARTMENT**

From:
V.Papaiah, M.Sc.B.Ed.
District Fire Officer,
East Zone, Hyderabad.

To
The District Educational Officer
Ranga Reddy District.

Re.No.44/DFO/EZ/HYD/2014/Dated: 17-02-2014

Sir,

Sub: A.P. State Disaster Response and Fire Services Department - East Zone - Hyderabad - Proposed for construction of Non-Multi Storeyed Educational Building of **M/s Edify World School in Sy.No.90 (Part), at Balapur Village, Saroornagar Mandal, Rangareddy District** by Sri V. Vijaya Simha Reddy and Smt. G.Padma, H.No. 3-16-7, Indira Nagar, Ramanthpur, Ranga Reddy District- Issue of Provisional No Objection Certificate - Regarding.

Ref: 1) Application Dated 15-02-2014 of M/s. Edify World School, in Sy.No.90 (Part), at Balapur Village, Saroornagar Mandal, Rangareddy District.
2) Inspection Report of the Asst. District Fire Officer, Maheshwaram and Station Fire Officer, Hayathnagar .Dated: 13-02-2014.

I submit that, the Asst. District Fire Officer, Maheshwaram and Station Fire Officer, Hayathnagar have inspected the proposed site and scrutinized the plans and submitted. inspection report vide in reference 2nd cited. This office Provisionally No Objection for construction of Non-Multi Storeyed Educational Building of **M/s M/s Edify World School in Sy.No.90 (Part), at Balapur Village, Saroornagar Mandal, Rangareddy District.**

2} The Builder has proposed to construct a Non-Multistoried Educational Building with Ground + 2 Upper Floor with a height of **09.00 metres** for Educational Occupancy (B-2).

3} PARTICULARS OF THE BUILDING:-

a)	Address of the building	M/s Edify World School in Sy.No.90 (Part), at Balapur Village, Saroornagar Mandal, Rangareddy District.
b)	Built-up area/height of the building	2750.65 sq.meters / 09.00 meters
c)	No of blocks / floors	One Block / Ground Floor + 2 Upper Floors
d)	Type of occupancy	Educational Building (B-2)

(P.T.O)

PRINCIPAL
EDIFY WORLD SCHOOL
Balapur, Hyderabad.



4} Floor Wise details:

Sl. No.	Floor	Area in Sq. Mtrs	Occupancy (Educational/ Hostel/Dormitory Occupancy)	Maximum Occupant load permissible as per NBC-2005
1.	Ground Floor	889.63	Educational Occupancy (B-2)	223
2.	First Floor	930.51	Educational Occupancy (B-2)	223
3.	Second Floor	930.51	Educational Occupancy (B-2)	223
	Total	2750.65		

5} STAIRCASES: The details of staircases required as per NBC-2005.

Sl. No.	Detailing Staircases	Required		Builder proposed	Deficit
		Nos.	Width		
1.	Internal staircase	1 No	1.50 M	02.00 M	Nil
2.	External staircase	1 No.	1.25 M	02.68 M	Nil
	Total	2 No	2.75 M	04.68 M	

6} Open spaces all round building:

Side	Open space Required	Open space proposed by the Builder	Remarks/Deficit
East	06.00 meters	06.22 Meters	Nil
West	06.00 meters	06.22 Meters	Nil
North	06.00 meters	06.22 Meters	Nil
South	06.00 meters	06.22 Meters	Nil

7} The builder proposed to provide the following fire safety measures as per Table 23 of Part-4 of NBC of India 2005.

Sl.No.	Fire Safety measures as per table-23, Part-IV of NBC-2005	Required	Proposed to Provide	Deficit
1	Fire extinguishers as per IS 2190:1992	6 Nos	6 Nos	Nil
2	Hose Reel	01 Nos in each Floor	01 Nos in each Floor	NIL
3	Down comer	01 Nos	01 Nos	Nil
4	Terrace Tank	10,000 Ltrs	20,000 Ltrs	Nil
5	Booster Pump	450 LPM	450 LPM	Nil

Yours faithfully,

[Signature]
17/02/2014
District Fire Officer,
East Zone, Hyderabad

[Signature]
17/2/14

PRINCIPAL
EDIFY SCHOOL
Balepu, Hyderabad.